

APPLICATION No.:

## TAP CLEARED

LOCATION: Fort Rodman

OWNER: Boat House

T-75

## MEASURES:

Dec. 18, 1987 Replaced broken 1" curb stop with brand  
new stop. At same location ( could not turn old one)  
-----

July 23, 1998 Tap was pulled from main while excavating. Repaired with 1" tap,  
3.4 ft. - 1" Copper tubing, 1 - 1" x 1" cop to cop cplg. to existing service for Bldg. T75  
Note: 1" tap is 0.8" South of #441 Cplg.  
-----

8-5-98 Renewed from main to curb stop. Stock: 9ft. - 1" Copper tubing,  
1 - 1" Curb Stop .

DATE

BEF.

AFT.

REMARKS

[illegible]

## CHARGE OUTS

[illegible]